[25th January 1961

THE HON. SRI M. A. MANICKAVELU: இது நிர்வாகத் தேவைக்காக செய்யப்படுகிறது.

SRI A. K. THANGAVEL MUDALIAR: அடிக்கடி மாவட்ட கலெக்டர்களே மாற்றுவதால், மாவட்ட நிர்வாகம் சீரான நிலையில் இல்லை என்பது அரசாங்கத்திற்குத் தெரியுமா?

THE HON. SRI M. A. MANICKAVELU: இதிலே மாற்ற வேண்டிய அவசியம் இருந்தது. ஒன்றிரண்டு பேருக்கு மேல் உத்தியோகத்திற்கு பிரமோஷன் வருகிறது. அதை எப்படித் தடுப்பது? தடுக்க முடியாது. (சிரிப்பு.)

Tiruvalangadu

* 34 *Q.*—VIDWAN T. MUTHUKANNAPPAN (on behalf of SRI A. GAJAPATHY NAYAGAR: Will the Hon. the Minister for Revenue be pleased to state whether there is any ppropposal to shift the headquarters from Manur to Tiruvalangadu in Tiruttani taluk?

THE HON. SRI M. A. MANICKAVELU: No, Sir.

Poonamallee Panchayat

* 35 *Q.*—DR. A. SREENIVASAN: Will the Hon. the Minister for Electricity be pleased to state—

(*a*) the number of occasions of failure of electricity in Poonamallee Panchayat from January to March 1960;

(*b*) the duration of failure on each occasion; and

(*c*) the causes for the failure?

THE HON. SRI V. RAMAIAH: (*a*) Forty-six.

(*b*) A statement is placed on the table of the House.

(*c*) Break-down of feeder, pre-arranged shut-down, emergency shut-down for rectification of switch, tripping of the feeder to clear temporary faults, load shedding and low tension shut-down for carrying out minor rectifications on lines.

DR. A. SREENIVASAN: Is it not a fact that electricity failed in the Poonamallee Panchayat on a number of occasions for hours together and some times for even days? If it is only a question of repair, how can electricity fail for hours on end?

THE HON. SRI V. RAMAIAH: I have placed a statement [a] on the table of the House. If the hon. Member would go through it he will find that his supplementary question that electricity failed for days together is not waranted. Neither was inconvenience caused for hours together. The longest period at one time was eigth hours. It must be due to repair being carried out on some lines.

---

[a] Printed as Appendix III on pages 199–200 infra.